

Emission Test Certificate

Wednesday, September 23th, 2015

Supplier: Inovar Floor (2 Wella Way, SOMERSBY, NSW, 2250)

Sample Description: Inovar Floor – 12 mm Long Board

Date Tested: September 2015 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

Green Building Council of Australia	Inovar Floor – 12 mm Long Board
Total Volatile Organic Compound Emission Rate limit <math><0.5\text{mg}/\text{m}^2/\text{hr}</math>	Total Volatile Organic Compound Emission Rate: $0.028\text{ mg}/\text{m}^2/\text{hr}$
Formaldehyde Emission limit $\leq 0.124\text{ mg}/\text{m}^3$	Formaldehyde Emission: $0.047\text{ mg}/\text{m}^3$



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
PhD, B.E Chem.
Consultant



Nick Joy
BSc (Hons)
Consultant

CV150909