

**TABLE 3B**  
**WET PENDULUM TEST OR OIL-WET INCLINING PLATFORM**  
**CLASSIFICATIONS FOR APPLICATIONS WHERE THE NCC DOES NOT**  
**REQUIRE SLIP RESISTANCE**

Location	Wet pendulum test	Oil-wet inclining platform test
<b>External Pavements and Ramps</b>		
External ramps including sloping driveways, footpaths etc. steeper than 1 in 14	P5	R12
External ramps including sloping driveways, footpaths, etc., under 1:14, external sales areas (e.g. markets), external carpark areas, external colonnades, walkways, pedestrian crossings, balconies, verandas, carports, driveways, courtyards and roof decks	P4	R11
Undercover car parks	P3	R10
<b>Hotels, Offices, Public Buildings, Schools and Kindergartens</b>		
Entries and access areas including hotels, offices, public buildings, schools, kindergartens, common areas of public buildings, internal lift lobbies		
Wet area	P3	R10
Transitional area	P2	R9
Dry area	P1 (see Note 3)	R9
Toilet facilities in offices, hotels and shopping centres	P3	R10
Hotel apartment bathrooms, en suites and toilets	P2	A
Hotel apartment kitchens and laundries	P2	R9
<b>Supermarkets and Shopping Centres</b>		
Fast food outlets, buffet food servery areas, food courts and fast food dining areas in shopping centres	P3	R10
Shop and supermarket fresh fruit and vegetable areas	P3	R10
Shop entry areas with external entrances	P3	R10
Supermarket aisles (except fresh food areas)	P1 (see Note 3)	R9
Other separate shops inside shopping centres—wet	P3	R10
Other separate shops inside shopping centres—dry	P1 (see Note 3)	R9
<b>Loading Docks, Commercial Kitchens, Cold Stores, Serving Areas</b>		
Loading docks under cover and commercial kitchens	P5	R12
Serving areas behind bars in public hotels and clubs, cold stores and freezers	P4	R11
<b>Swimming Pools and Sporting Facilities</b>		
Swimming pool ramps and stairs leading to water	P5	C
Swimming pool surrounds and communal shower rooms	P4	B
Communal changing rooms	P3	A
Undercover concourse areas of sports stadiums	P3	R10
<b>Hospitals and Aged Care Facilities</b>		
Bathrooms and en suites in hospitals and aged care facilities	P3	B
Wards and corridors in hospital and aged care facilities	P2	R9